

Intertek Caleb Brett
Report of Analysis

Vessel / Tank Submitted Sample
Lab Ref No 2007-0974
Terminal / Port Total Fuel Solutions LLC
Submitted by Total Fuel Solutions LLC
Designated as Diesel
Date Sampled
Date Submitted 09/18/07
Sample(s) Tested Treated Diesel

Our Ref Number T832
Customer Ref No
Date Tested 09/18/07

Method	Test	ASTM D975	Results	Units
ASTM D6079	Lubricity, HFRR Temperature	520 μ m Max	267 60	μ m °C


 Daniel L. Thompson
 Laboratory Manager
 Intertek Caleb Brett