


Intertek Caleb Brett**Report of Analysis**

Vessel / Tank Submitted Sample
Lab Ref No 2007-0974
Terminal / Port Total Fuel Solutions LLC
Submitted by Total Fuel Solutions LLC
Designated as Diesel
Date Sampled
Date Submitted 09/18/07
Sample(s) Tested Treated Diesel

Our Ref Number T832
Customer Ref No
Date Tested 09/18/07

Method	Test	Colonial Pipeline	Results	Units
ASTM D2274	Oxidation Stability	2.5 mg/100mL Max	1.0	mg/100mL


Daniel L. Thompson
Laboratory Manager
Intertek Caleb Brett